

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0065:173

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detectors

**LISTEE:** Faraday Inc., 805 S. Maumee Street, Tecumseh, MI 49286  
Contact: Steve Blohm (517) 423-2111

**DESIGN:** Models 8810 and 8811 photoelectric type smoke detectors. Model 8811 employs an integral supplemental 135 °F fixed temperature heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For wall and ceiling mount.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric type smoke detectors for use with separately listed compatible fire alarm control units and Model 8853 or 8816 base (CSFM Listing No. 7300-0065:158). Suitable for duct application where air velocity is between 0-4000 ft/min.

07-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager